

Lead and Copper Rule Revisions/Improvement (LCRR/LCRI) Deadlines*

Developed by the NEWWA Corrosion Control Committee

System Requirements	Compliance Date
Initial inventory development and submission of initial inventory to the State	October 16, 2024
Failure to submit initial inventory to the State by October 16, 2024, requires Tier 3 Public Notification (PN)	Starting October 16, 2024
Issue notification of known, potential lead service lines, galvanized requiring replacement (GRR) or unknown within 30 days of completion of the initial inventory and repeat notification on an annual basis until the service line is no longer lead, potential lead, GRR or unknown. For new customers, systems must provide the notification at the time of service initiation.	Within 30 days of completion of the inventory and then annually
Provide revised lead health effect language in public education materials (including public education after a lead action level exceedance)	Starting October 16, 2024
Failure to certify to the State that the system notified persons served by lead, GRR, potential lead/or unknown service line requires Tier 3 PN	Starting October 16, 2024
Exceedance of the lead action level requires Tier 1 PN no later than 24 hours after the system learns of the exceedance Note: Revised lead action level of 10 ppb will be effective on November 1, 2027	Starting October 16, 2024
A copy of the Tier 1 PN for lead action level exceedance must be sent to the State and EPA at LEADALE@EPA.gov no later than 24 hours after the system learns of the exceedance	Starting October 16, 2024
Annual certification to the state by July 1 that the system provided notification and delivered lead service line information materials to affected consumers with lead, GRR or unknown service lines for the previous calendar year Systems must provide a copy of the notification and lead service line information materials to the State	July 1, 2025 and then after the end of the first program year (November 1, 2027 to December 31, 2028). Thereafter, annually by January 30
Baseline inventory	By November 1, 2027
Updated inventory	After the end of the program year 1 (by January 30, 2029) and every January 30th thereafter
Waiver request for non-lead validation must be submitted to the State	By November 1, 2027
Waiver request for lead water testing in schools and childcare facilities must be submitted to the State	By November 1, 2027
Service line replacement plan must be submitted to the State and make public accessible	By November 1, 2027
All community systems must submit a list of schools and licensed childcare facilities they serve or provide certification that they do not serve any Systems must provide annual public information on health risk from lead Systems must collect samples annually from at least 20% of the total schools and childcare facilities	Starting November 1, 2027
Revised health effect language from Lead and Copper Rule Improvements (LCRI) This applies to public education materials, PN, and Consumer Confidence Report (CCR)	November 1, 2027
Additional requirements related to LCRI amended to CCR	November 1, 2027
Tap sampling plan and instructions to residents must be submitted to the State	By January 1, 2028
Validation of non-lead service lines	No later than December 31, 2034, or state designated schedules
Mandatory service line replacement	10 years or state designated timelines

*This document is intended to be used for informational purposes only and specific compliance dates and requirements may differ based on your location. For the most up to date information, you should reach out to your State Regulatory Agency.